





This label is edited by Hitachi's "ErP Active Tool". Ecodesign implementation, in accordance with Annex III of Regulation (EU) No 626/2011 of 4 May 2011, supplementing Directive 2010/30/Eu labeling of equipment air conditioning equipment.

SEER : seasonal performance of the equipment running in cooling mode; The highest is the value, the lowest will be the consumption. Regulation requires for any new product introduced in Europe since 01/01/2013 a minimum value of SEER of 3.6 (D class). **D**

For more precise information on seasonal performance of the equipment, refer to the values of SCOP and annual consumption (kWh/year).

Indoor Unit sound power level

Outdoor Unit sound power level



SCOP : seasonal energy performance of the equipment operating in heating mode; The higher is the value, the lowest will be the consumption. Regulation requires for any new product introduced in Europe since 01/01/2013 a minimum value of SCOP on average climate of 3.4 (A class). **A**

For more precise information on seasonal performance of the equipment, refer to the values of SCOP and annual consumption (kWh/year).

| Climates defined by regulation | Lowest outdoor temperature | City used as reference | Heating period (hours/days) |
|--------------------------------|----------------------------|------------------------|-----------------------------|
| Warm                           | +2° C                      | Athene                 | 3590 h / 149 d              |
| Average                        | -10° C                     | Strasbourg             | 4910 h / 204 d              |
| Cold                           | -22° C                     | Helsinki               | 6646 h / 277 d              |

For heating operation, displayed informations related to the energy consumption are compulsory for average climate. Other climates are optional.